

CORRIGENDUM -2 FOR NIT: CMC/BR/19-20/SV/RS/KG/885_SURVEY, DESIGN, SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF 66/11 KV GIS GRID SUBSTATION ON SINGLE POINT RESPONSIBILITY BASIS FOR PROVIDING NEW CONNECTION OF 8MW IN F/O DGHS-1725 BEDS HOSPITAL, SEC-9 DWARKA

CORRIGENDUM DATE: 11th Jan 2021

Sl. No.	Clause no.	Clause Description	Revised
1	Section-I RFQ; Clause no 2c Technical Qualification Criteria	The GIS offered should have been successfully type-tested as per relevant IEC and copies of the test reports latest for max 5 years shall be submitted along with the offer. Non submission of type test reports will lead to rejection of the offer.	<p>The GIS offered should have been successfully type-tested within past Five (5) years from date of Bid opening as per relevant IEC and copies of the test reports latest for the same shall be submitted along with the offer. In case type test reports are older than five (5) years from the date of bid opening, bidder shall submit the undertaking that there is ""since the last type test, the product has not undergone any change in design and the materiel used and the dimensions of the product are the same as the one on which the type test was conducted".</p> <p>Non submission of type test reports will lead to rejection of the offer. Type test older than ten (10) years shall not be acceptable and bid is liable for rejection.</p>
2	Section-I RFQ; Clause no 2e Financial Qualification Criteria	The bidder must possess valid ISO 9001:2000 certification and valid BIS License or Equivalent International License.	The bidder must possess valid ISO 9001:2000 certification
3	Section-I RFQ; Clause no 2 Qualification Criteria	Additional Clause	<p>For either of the PQR conditions listed below as 1, 2 & 3 , in case bidder is 100% owned subsidiary of their parent organization, credential of the parent organization shall be considered as a compliance to the QR requirements as listed , subjected to the fulfilment of the conditions as specified as (a) and (b):</p> <p>In case bidder is 100% owned subsidiary of their parent organization then the credentials of the parent organization shall be considered as compliance to the QR requirement as listed below.</p>

			<p>The QR parameters against which the bidder can submit the credential of their parent company are as below:</p> <ol style="list-style-type: none"> 1. Bidder shall submit the performance certificates for One (1) year satisfactory performance from two (2) reputed electricity board/transmission and distribution utilities for executed jobs. 2. The bidder must have designed, supplied, installed & commissioned at least two (2) nos of GIS grid substation of similar rating or higher rating including civil works in last Five (5) years in India (Turnkey Basis). The list of such installations shall be furnished (list of installation). 3. Bidder must have average annual turnover of minimum Rs 50 crores during last Three (3) years . <p>For either of the above PQR conditions listed as 1, 2 & 3 , in case bidder is 100% owned subsidiary of their parent organization, credential of the parent organization shall be considered as a compliance to the QR requirement , subjected to the fulfilment of the following conditions :</p> <p>a) The submission of Additional 5% contract performance bank Guarantee (CPBG) from the parent company (whose credential has been submitted against the QR requirement) This bank Guarantee shall be over and above the 10% CPBG as per NIT conditions.</p> <ul style="list-style-type: none"> • Parent organization shall submit the additional BG from Indian Bank only. • Additional BG shall be given by Parent company on behalf of the 100% Indian subsidiary company to M/s. BRPL against the said tender NIT No-CMC/BR/20-21/SV/RS/KG/885 , against which Parent company credential have been submitted to BRPL for the purpose of vendor qualification of 100% Indian subsidiary Company.
--	--	--	--

			<ul style="list-style-type: none"> • In case of any default in the performance of the contract in terms of supplies/timely execution/ performance of the equipment /contract, BRPL shall raise the invocation notice to Indian subsidiary company only for both BGs i.e one submitted by the bidder (Indian Subsidiary) and the other submitted by the parent company and parent company shall have "NO Objection " in this regard. <p>b) Extended warranty of two (2) years from the bidding Company for the installed GIS grid.</p> <p>ALL OTHER TERMS AND CONDITIONS OF THE NIT, INCLUDING BALANCE QUALIFYING CONDITIONS, SHALL REMAIN THE SAME.</p>
--	--	--	--