

**Amendment No. 1**

<b>RATE CONTRACT FOR SUPPLY OF VARIOUS RATINGS OF AIR CIRCUIT BREAKER IN BRPL (CMC/BR/25-26/FK/PR/SN/1243 )</b>			
<b>Sr no</b>	<b>Specification Clause</b>	<b>Existing Clause</b>	<b>Amended/Additional Clause</b>
1	12.7	<p>a) A suitable resettable PRD/ explosion vent shall be provided to move out hot gases in case of any internal arc in ACB enclosure. [R1]</p> <p>b) Position of PRD/ explosion vent shall be rear side of top cover of ACB enclosure to ensure safety of operator.[R1]</p>	Rubber Grommet shall be provide at back side of the Enclosure
2	Additional points	_____	<p>__Hand Lifting handles shall be provided at side walls of ACB</p> <p>__Support insulators shall be provided between incoming and outgoing bus bar (all phases and neutral) for all ratings except 400 A.</p> <p>__Operation door shall be hinged from top side using concealed and non removable type hinges. Stopper shall also be provided in operation door. _____Release display shall be powered on even in case of No load condition</p>