

S.No.	Tech. Specification clause no:	Clause Title	Original Clause Description	Revised Clause Description
1	13.2	Additional Requirements	a) Complete connections including incoming and outgoing busbars shall be inside the metal enclosure b) Appropriate support shall be provided to incoming and outgoing busbars through support insulators c) Stand of 900 mm height shall be integrated with the ACB enclosure. d) For ACBs of higher ratings i.e 2000A and above, incoming connection should be placed below the ACB and outgoing connection should be placed at the rear of ACB. Please refer annexure 'B' for reference design.[R1]	a) Complete connections including incoming and outgoing busbars shall be inside the metal enclosure b) Appropriate support shall be provided to incoming and outgoing busbars through support insulators c) For ACBs of higher ratings i.e 2000A and above, incoming connection should be placed below the ACB and outgoing connection should be placed at the rear of ACB. Please refer annexure 'B' for reference design.[R1]
2		NIT Price format	----	Trial order quantities 2000 Amp Type 2 ACB- 2 nos 3200 Amp Type 2 ACB- 2nos