

# TECHNICAL SPECIFICATION

FOR

# FRLS CONTROL CABLE

# SPECIFICATION NO. - BSES-TS-57-CCAB-R0.

Rev:	N 3	0
Pages:		11
Date:	Section 1	20 April 2022
	Abhishek Vashistha	dit
Prepared by	Rohit Patil	PAL.
	Puneet Duggal	to-
Reviewed by	Amit Tomar	Jistre
	Gaurav Sharma	Cearman
Approved by	Gopal Nariya	OH F
	AND IT AT A DUILTY STOREMENT OF A DUILTY STORE AND A DUILTY ST	



# **INDEX**

1.0	SCOPE	3
2.0	STANDARDS & CODES	3
3.0	SERVICE CONDITIONS	4
4.0	DESIGN FEATURES	4
5.0	QUALITY ASSURANCE PLAN, INSPECTION AND TESTING	6
6.0	PACKING, SHIPPING, HANDLING & SITE SUPPORT	7
7.0	DEVIATIONS	7
8.0	DOCUMENT SUBMISSION MATRIX	8
Annex	kure – A: Guaranteed Technical Particulars (Data by Supplier)	9



#### 1.0 SCOPE

The scope of supply includes Design, Manufacture, Testing at manufacturer's works before dispatch, packing, delivery including unloading and stacking at site/store of Control Cable complete with all accessories.

#### 2.0 STANDARDS & CODES

Materials, equipments and methods used in the manufacture of Cable shall conform to the latest edition of following:

S No.	STANDARD	DESCRIPTION	
2.1	IS- 1554 Part-1	PVC insulated Cables	
2.2	IS- 5831 : 1984	PVC insulation & sheath of electric cables.	
2.3	IS- 10810 : 1984	Methods of test for cables.	
2.4	IS- 8130 : 1984	Conductors for insulated electric cables and flexible cords.	
2.5	IS- 3961 Part 2	Recommended current ratings for PVC insulated and PVC sheathed heavy duty Cables	
2.6	IS- 3975 : 1999	Mild steel wires, formed wires and tapes for armouring of cables.	
2.7	IS- 10418 : 1982	Drums for Electric Cables	
2.8	IEC 60228 Ed.3.0 b	Conductors of insulated cables.	
2.9	IEC 60332-3-21 Ed.1.0 b	Tests on electric cables under fire conditions. Part 3-21. Tests on bunched wires or cables.	
2.10	IEC 60502-1 Ed. 2.1 b	Power cables with extruded insulation and their accessories for rated voltage from 1kV upto 30kV –Part 1: cables for rated voltages of 1kV and 3kV	
2.11	IEC 60811	Common test methods for insulating and sheathing materials of electric cables.	
2.12	IEC 60885 Ed.1.0 b	Electric test methods for electric cables.	
2.13	IEC 60227	PVC insulated cables of rated voltages up to and including 450/750 V.	
2.14	IEC 60028 Ed. 2.0 b	International Standard of Resistance for Copper	
2.15	ASTMD 2843	Standard Test Method for density of Smoke from the burning or decomposition of cables	
2.16	ASTM 2863	Standard Test Method for measuring of minimum oxygen concentration	
2.17	IEC 60754-1	Test on gases evolved during combustion of materials for cables. Part 1 – Determination of the Halogen Acid gas Content	



#### 3.0 SERVICE CONDITIONS

Control Cables to be supplied against this specification shall be suitable for satisfactory operation under the following conditions-

3.1	Average grade atmosphere	Heavily polluted, Dry	
3.2	Maximum altitude above sea level	1000M	
3.3	Relative Humidity	100%	
3.4	Ambient air temperature	Highest 50 Deg C Average 40 Deg C Minimum 0 Deg C	
3.5	Operating temperature	0 Deg C - 50 Deg C	
3.6	8   Rainfall   750mm concentrated in four mo		

#### 4.0 DESIGN FEATURES

(Refer Annexure – "A")

S No.	Parameters	Technical Requirements	
4.1		Size & dimensions of each item mentioned under this clause shall be followed as detailed out in GTP, refer Annexure A	
4.2	Conductor	<ul> <li>Stranded, plain copper, circular</li> <li>Shall be made from high conductivity copper rods</li> </ul>	
4.3	Insulation	Extruded PVC Insulation Type A as per IS 5831	
4.4	Core Identification	As per IS 1554 Part 1	
4.5	Inner Sheath	Extruded Inner Sheath of Black PVC type ST-2 as per IS 5831	
4.6	Armour	<ul> <li>As per Clause 13.2 of IS 1554 Part-1: Galvanized steel round wire armour.</li> <li>Minimum area of coverage of armouring shall be not less than 90 %. (refer Annex C of IS 1554-part 1 for % calculation)</li> </ul>	



S No.	Parameters	Technical Requirements	
4.7	Outer Sheath FRLS Properties	<ul> <li>a) Extruded outer sheath of PVC type ST-2 as per IS 5831 having FRLS properties</li> <li>b) Color : Black</li> <li>c) The Outer Sheath shall be embossed with: <ol> <li>The voltage designation</li> <li>Type of construction / cable code (for e.g. AYWY)</li> <li>Manufacturers Name or Trade mark</li> <li>Number of Cores and nominal cross sectional area of conductors</li> <li>Number of Cores and nominal cross sectional area of conductors</li> <li>The drum progressive length of cable and individua drum number at every meter. (By Printing)</li> <li>Name of buyer i.e. BSES</li> <li>Month &amp; Year of Manufacturing</li> <li>P.O. No. and P.O. Date</li> </ol> </li> <li>a) Oxygen Index : Not less than 29% as per ASTM 2863</li> <li>b) Temperature Index: 250°C at Oxygen Index 21 (whe tested as per ASTM D 2863)</li> <li>c) Max Acid Gas Generation – Not more than 20% as per</li> </ul>	
		<ul> <li>IEC -60754-1</li> <li>d) Light Transmission - Minimum 40% when tested as per ASTMD 2843 (Smoke Density rating shall be max 60%)</li> <li>e) Flammability Test - As per IEC 60332-III, Cat - B, IEC 60332- I, IS- 10810 - Part 53, IS:10810 - Part 61 &amp; 62 (Category A)</li> </ul>	
	Sealing of cable end	Both ends of the cable shall be sealed with PVC Cap.	
4.10	Drum length & tolerance	500 mtr (+/- 5%)	
4.11	Overall tolerance in cable length	- 2 %	
4.12	Short length of cables	<ul> <li>a) Minimum acceptable short length shall be above 100 meters. Manufacturer shall be required to take prior approval from engineering for any short length supply.</li> <li>b) Manufacturer shall not be allowed to put two cable pieces of different short lengths in same cable drum.</li> <li>c) Only 1% of the total ordered quantity.</li> </ul>	



## 5.0 QUALITY ASSURANCE PLAN, INSPECTION AND TESTING

S No.	Parameters	Technical Requirements	
5.1	Quality Assurance Plan	QAP Shall be submitted by vendor for approval. Inspection and testing of the material shall be carried out accordingly.	
5.2	Type test	Cables must be of type tested as per relevant IS/IEC/ASTM. Type test conducted either from CPRI/ERDA/NABL third party accredited lab will be treated as valid. Type test reports shall be submitted for the type, size & rating of cable offered along with bid.	
5.3	Routine test	Each drum length of cable shall be subjected to the routine tests as mentioned in IS 1554 part -1	
5.4	Acceptance Tests	The sampling & acceptance tests Shall be conducted, as per IS 1554 Part-1 and approved QA plan, for each lot of cable during the inspection of lot at manufacturer's works.	
5.5	Inspection	<ul> <li>a) The buyer reserves the right to inspect cables at the Seller's works at any time prior dispatch, to verify compliance with the specifications.</li> </ul>	
		<ul> <li>b) In-process and final inspection call intimation shall be given in 15 days advance to purchaser.</li> </ul>	
		c) In the event of any discrepancy in the test reports i.e. test reports not acceptable or any type tests (including special /additional tests, if any) not carried out, same shall be carried out without any cost implication to BSES before dispatch of cable.	
5.6	Test certificates	Test certificates (routine and acceptance) shall be submitted along with the dispatch documents.	



#### 6.0 PACKING, SHIPPING, HANDLING & SITE SUPPORT

6.1	Packing	The cable shall be wound on wooden drums (with anti termite treatment and M.S. spindle plate with nut-bolts). Cable should be packed conforming to Indian / international standards. The drum shall be fully enclosed by suitable packing preferably PP sheeting.	
6.2	Drum identification label	<ul> <li>The following information shall be marked on the drum:</li> <li>a) Drum identification number</li> <li>b) Trade name or trade mark; if any</li> <li>c) Name of manufacturer</li> <li>d) Name of buyer i.e. BSES</li> <li>e) Cable voltage grade</li> <li>f) Cable code (e.g. YWY)</li> <li>g) Number of cores and cross sectional area</li> <li>h) Purchase order number with SAP item code</li> <li>i) Year and month of manufacturing</li> <li>j) Direction of rotation of drum (an arrow)</li> <li>k) Net weight of cable in drum and gross weight of cable with drum</li> <li>l) Batch no or Lot no.</li> <li>m) Cable length initial reading &amp; end reading shall be marked on drum. Cable starting end shall be taken out from winding to read this drum reading with proper sealing to protect against external damage.</li> </ul>	
6.3	Shipping	The seller shall give complete shipping information concerning the gross weight, size of each packing.	
6.4	Handling & Storage	Manufacturer instruction shall be followed. Detail handling & storage instruction sheet/manual needs to be furnished before commencement of supply.	
6.5	Transit damage	The seller shall be responsible for any transit damage due to improper packing.	

#### 7.0 DEVIATIONS

7.1	Deviation	Deviations from this Specification shall be stated in writing with the tender by reference to the Specification clause/GTP/Drawing and a description of the alternative offer. In absence of such a statement, it will be assumed that the bidder complies fully with
		this specification.



#### 8.0 DOCUMENT SUBMISSION MATRIX

Document/Drawing submission shall be as per the matrix given below. All documents/drawings shall be provided in soft copy only in returnable Pen drives. Language of the documents shall be English only. Incomplete submission shall be liable for rejection.

S No.	Description	Bid	Approval	Pre Dispatch
8.1	Guaranteed Technical Particulars (GTP)	required	required	
8.2	Deviation Sheet, if any	required	required	
8.3	Detailed cross sectional drawing of cable	required	required	
8.4	Dimensional drawing of Cable Drum		required	
8.5	Type test reports for the offered type and rating of cable	required	required	
8.6	BIS Certificate	required		
8.7	Make of Raw Materials	required	required	
8.8	Cable de-rating factors	required	required	
8.9	Manufacturer's Quality Assurance Plan		required	
8.10	Detailed installation & commissioning instructions		required	
8.11	Test certificates of all raw materials			required
8.12	Inspection and routine test reports, carried out in manufacturer's works			required



#### Annexure – A: Guaranteed Technical Particulars (Data by Supplier)

#### (Standard Cable sizes are 2Cx2.5, 4Cx2.5, 6C X 2.5, 8Cx2.5, 10Cx2.5, 12C X 2.5 mm<sup>2</sup>)

#### For each size separate GTP need to be furnished

# \*For any size other than standard sizes mentioned, GTP should be as per IS or requirement whichever applicable

Sr.	Description	Buyer's requirement	Vendor's Data
	Purchase Req. No.		
	Guarantee Period: 5 Years	60/66 Months	
1.0	Make	To be specified by vendor	
2.0	Type(AS PER IS 1554 part -1)	YWY	
3.0	Voltage Grade (KV)	1.1	
4.0	Maximum Conductor temperature		
a)	Continuous (° C)	70°C	
b)	Short time (° C)	160°C	
5.0	Conductor		
a)	Size (mm <sup>2</sup> )	2.5	
b)	No. of wires in each conductor	As per Manufacturer standard	
c)	Dia. of wires in each conductor before compaction (mm)	As per Manufacturer standard	
d)	Shape of Conductor	As per Clause 4.2 of specification	
e)	Diameter over conductor mm	To be specified by vendor	
f)	Maximum Conductor resistance at20 ° C(Ohm/Km)	As per Table 2 of IS 8130	
6.0	Insulation	As per Table 1 of IS:5831 – 1984	
a)	Nominal thickness (mm)	As per Clause 4.3 of	
b)	Minimum thickness (mm)	specification & Table 2 of IS 1554( Part-1)	
c)	Core Identification	As per IS 1554 Part 1	
d)	Approx. dia. over Insulation (mm)	To be specified by	



Sr.	Description	Buyer's requirement	Vendor's Data
		vendor	
7.0	Inner Sheath	As per Table 2 of IS:5831 – 1984	
a)	Minimum thickness (mm)	As per Table 4 of IS 1554(Part-1)	
b)	Approx. dia. Over sheath (mm)	To be specified by vendor	
8.0	Galvanized Steel Armour	As per IS 1554-part 1	
a)	Number of armour wire	As per Manufacturer Std.	
b)	Nominal dia. of Round Wire	As per Table 5 of IS 1554(Part-1)	
c)	Dia. over armour – approx.	To be specified by vendor	
d)	Lay Ratio	To be specified by vendor	
e)	Confirm minimum 90% coverage (submit calculation)		
. 9.0	Outer Sheath (FRLS)	As per Table 2 of IS:5831 – 1984	
a)	Thickness (min)	As per Table 7 of IS 1554(Part-1)	
b)	Color	Black	
10.0	Approx. overall dia. (mm)	To be specified by vendor	
11.0	Drum length & tolerance	As per clause 4.10 of specification	
12.0	End Cap	Required	
13.0	Drums provide with MS Spindle plate & Nut bolts arrangement	Required	
14.0	Net Weight of cable (Kg/Km.) – approx.	To be specified by vendor	



Sr.	Description	Buyer's requirement	Vendor's Data
15.0	Continuous current rating for standard I.S. condition laid Direct		
a)	In ground 30° C Amps	To be specified by vendor	
b)	In duct 30° C Amps	To be specified by vendor	
c)	In Air 40° C Amps	To be specified by vendor	
16.0	Short circuit current for 1 sec of conductor. (KAmp)	To be specified by vendor	
17.0	Electrical Parameters at Maximum Operating temperature:		
a)	Resistance (Ohm/Km ) (AC Resistance)	To be specified by vendor	
b)	Reactance at 50 C/s (Ohm/Km)	To be specified by vendor	
c)	Impedance(Ohm/Km)	To be specified by vendor	
d)	Capacitance (Micro farad / KM)	To be specified by vendor	
18.0	Recommended minimum bending radius	x O/D	
19.0	FRLS Properties		
a)	Oxygen Index	To be specified by vendor	
b)	Temperature Index	To be specified by vendor	
c)	Max Acid Gas Generation	To be specified by vendor	
d)	Light Transmission / Smoke Density	To be specified by vendor	