Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: APRIL 2017-Dec 17
Year: 2017

Sl. No.	Location of accident and details of victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	H.no. 556/31, Gali-15, Vijay Park, Division-YVR Victim: Mr. Ashok(Public)	4 MAY 17	FATAL	ELECTROCUTION FROM POLE	No earth connection of street light pole			Earth connection provided	
2	Near C-4/90A, gantry of 66kV Ghonda to Bhagirathi Ckt no 2 Victim: Unknown (Public)	14 MAY 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Report not received				
3	H.no. D-21/4, Gali No 3, Shastri Park, Division- YVR Victim: Ms. Nisha (Public)	15 MAY 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Report not received				
4	Gate no 1, Pocket A, Dilshad Garden, Division- GTR Victim: Mr. Robin (Public)	21 MAY 17	FATAL	SNAPPING OF CONDUCTOR	No earth guarding			Guarding provided	
5	Cycle market, New Lajpat Rai Mkt, Division-Chandni Chowk Victim: Unknown	21 MAY 17	FATAL	CURRENT LEAKAGE AT METER OUTGOING	Report not received				
6	2A/22, Geeta Colony, Division- KNR Victim: Unknown	7 AUG 17	FATAL	ELECTROCUTION	Report not received				

	(Public)								
7	B-Block s/stn, Shriram Colony, Sonia Vihar, Division-KWN Victim: Master Ayaan, S/o Sh. Sattar	25 AUG 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Report not received				
8	C/o Sh. Keshav Ram Sharma, H.No. A-392, Gali no 9, Part 5, Sonia Vihar, Division-Karawal Nagar	09 DEC 17	NON FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION	Unauthorised extension in vicinity of high voltage distribution system	To take suitable steps to restrain unauthorised construction by pubic		Regular encroachment warning letter served.	
9	A/88 Khasra no 351-352, gali no 2, part 2, pehla pusta, sonia vihar, Karawal Nagar	16 DEC 17	FATAL	INTERFERENCE WITH ELECTRICAL INSTALLATION AND ENCROACHMENT	Report not received				

(Signature of the Licensee)