BSES Yamuna Power Limited

Shakti Kiran Building, Karkardooma
Delhi - 110032, India
Tel.: +91 11 3009 9999
Fax: +91 11 3999 9403
www.bsesdelhi.com

प्राप्त
दिनांक 20/1/14

Ref No: RA/13-14/BYPL/ 626

Date: 20th Jan 2014

To,

The Secretary
Delhi Electricity Regulatory Commission,
Viniyamak Bhawan, C- Block, Shivalik,
Malviya Nagar, New Delhi – 110017

Sub: Overall standards of performance of Discoms – Reliability Indices.

Ref: Our Letter's - RCM/BYPL/09-10/32 dated 29th Jan 2010.
RCM/09-10/BYPL/116 dated 25th June 2010

Madam,

We refer to the aforesaid Correspondence regarding the Annual review on actual Performance as prescribed in the Schedule II for the Delhi Electricity Supply Code and Performance Standards Regulation, 2007, in terms of Regulation 11.2 of DERC (Terms and Condition for determination of wheeling and Retail Supply Tariff) Regulations, 2007, accordingly, the Performance Parameters for the period of Dec 2013 are being submitted herewith (enclosed as Annexure – 1).

Thanking You,

Yours faithfully,

For **BSES Yamuna Power Ltd.**

(Aditya Pyasi)
Head Regulatory (BYPL)

Encl: As above

BSES Yamuna Power Limited

Shakti Kiran Building, Karkardooma
Delhi - 110032, India
Tel.: +91 11 3009 9999
Fax: +91 11 3999 9403
www.bsesdelhi.com

Ref No: RA/13-14/BYPL/ 626

Date: 20th Jan 2014

To,

The Secretary
Delhi Electricity Regulatory Commission,
Viniyamak Bhawan, C- Block, Shivalik,
Malviya Nagar, New Delhi – 110017

Sub: Overall standards of performance of Discoms – Reliability Indices.

Ref: Our Letter's - RCM/BYPL/09-10/32 dated 29th Jan 2010.
RCM/09-10/BYPL/116 dated 25th June 2010

Madam,

We refer to the aforesaid Correspondence regarding the Annual review on actual Performance as prescribed in the Schedule II for the Delhi Electricity Supply Code and Performance Standards Regulation, 2007, in terms of Regulation 11.2 of DERC (Terms and Condition for determination of wheeling and Retail Supply Tariff) Regulations, 2007, accordingly, the Performance Parameters for the period of Dec 2013 are being submitted herewith (enclosed as Annexure – 1).

Thanking You,

Yours faithfully,

For **BSES Yamuna Power Ltd.**

(Aditya Pyasi)
Head Regulatory (BYPL)

Encl: As above

Schedule–II

Overall Standards of Performance for December-2013

BSES *Yamuna Power Limited*

Sr No	Service Area	Overall Standard of Performance	December-2013		Total cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (C)
			Within Specified Time Limit	Above Specified Time Limit		Within Specified Time Limit	Above Specified Time Limit	
1	Normal Fuse-Off Calls	At least 99% calls received should be rectified within prescribed time limits in both Cities and Towns and in Rural areas	23824	54	23878	23824	54	99.77%
2	Line Breakdowns	At least 95% of cases resolved within time limit in both Cities and Towns and in Rural areas	396	2	398	396	2	99.50%
3	Distribution Transformer Failure	At least 95% of DTRs to be replaced within prescribed time limits in both Cities and Towns and in Rural areas	0	0	0	0	0	Nil
			0	0	0	0	0	Nil
4	Period of Scheduled Outage							
	Maximum Duration in a single stretch	At least 95% of cases resolved within time limit	301	0	301	301	0	100.00%
	Restoration of supply by 6:00 PM		301	0	301	301	0	100.00%
5	Street Light Faults							
	Rectification of line faults	At least 90% cases should be complied within prescribed time limits	1060	0	1060	1060	0	100.00%
	Replacement of fused/defective unit							
6	Continuity Indices							
	SAIFI	To be laid down by the Commission based on the targets proposed by the Licensees.(Projections for First control period has already been submitted to Comission)	0.07749					
	SAIDI		0.11165					
	MAIFI		0.00000					
7	Frequency Variation	To maintain supply frequency within range as per IEGC						
8	Voltage Unbalance	Maximum of 3% at point of commencement of supply						
9	Percentage Billing Mistakes	Not exceeding 0.2%	447	0	705275	447	0	0.06%
10	Percentage Faulty Meters	Not exceeding 3%	810	0	1379958	810	0	0.06%