BSES Yamuna Power Limited

Shakti Kiran Building, Karkardooma
Delhi - 110032, India
CIN : U74899DL2001PLC111525
Tel.: +91 11 3999 9808, 3999 7111
Fax: +91 11 3999 9765
www.bsesdelhi.com

Ref No: RA/14-15/BYPL/ 929

Date: 24th Sep 2014

To,

The Secretary
Delhi Electricity Regulatory Commission,
Viniyamak Bhawan, C- Block, Shivalik,
Malviya Nagar, New Delhi – 110017

Sub: Overall standards of performance of Discoms – Reliability Indices.

Ref: Our Letter's - RCM/BYPL/09-10/32 dated 29th Jan 2010.
RCM/09-10/BYPL/116 dated 25th June 2010

Madam,

We refer to the aforesaid Correspondence regarding the Annual review on actual Performance as prescribed in the Schedule II for the Delhi Electricity Supply Code and Performance Standards Regulation, 2007, in terms of Regulation 11.2 of DERC (Terms and Condition for determination of wheeling and Retail Supply Tariff) Regulations, 2007, accordingly, the Performance Parameters for the period of Aug 2014 are being submitted herewith (enclosed as Annexure – 1).

Thanking You,

Yours faithfully,

For **BSES Yamuna Power Ltd.**

(Aditya Pyasi)
Head Regulatory (BYPL)

Encl: As above

Schedule–II

Overall Standards of Performance for August-2014

BSES *Yamuna Power Limited*

			August-2014					
1	Normal Fuse-Off Calls	At least 99% calls received should be rectified within prescribed time limits in both Cities and Towns and in Rural areas	50217	145	50362	50217	145	99.71%
2	Line Breakdowns	At least 95% of cases resolved within time limit in both Cities and Towns and in Rural areas	657	1	658	657	1	99.85%
3	Distribution Transformer Failure	At least 95% of DTRs to be replaced within prescribed time limits in both Cities and Towns and in Rural areas	5	0	5	5	0	100.00%
			5	0	5	5	0	100.00%
4	Maximum Duration in a single stretch	At least 95% of cases resolved within time limit	14	0	14	14	0	100.00%
	Restoration of supply by 6:00 PM		14	0	14	14	0	100.00%
5	Rectification of line faults	At least 90% cases should be complied within prescribed time limits	1226	0	1226	1226	0	100.00%
	Replacement of fused/defective unit							
6	SAIFI	To be laid down by the Commission based on the targets proposed by the Licensees.(Projections for First control period has already been submitted to Comission)	0.22246					
	SAIDI		0.26403					
	MAIFI		0.00029					
7	Frequency Variation	To maintain supply frequency within range as per IEGC						
8	Voltage Unbalance	Maximum of 3% at point of commencement of supply						
9	Percentage Billing Mistakes	Not exceeding 0.2%	287	0	1404822	287	0	0.02%
10	Percentage Faulty Meters	Not exceeding 3%	1966	0	1417950	1966	0	0.14%