Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: Feb 2020
Year: 2020

Sl. No.	Location and details of Victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI /AEI	Remedies suggested by CEI/EI /AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	66 KV Gazipur Gantry at Gazipur Dairy Farm Road. Victim: Unknown	28 April 19	Fatal	Electrocution while stealing the earthing strips meant for cable & structure earthing inside the gantry.	-	-	-	-	-
2	Shop no. 2778, Cheera Khana market, S/D: Town Hall, Chandni Chowk Victim: Sh. Faheem , Lineman, M/s Parihar Electricals	25 May 19	Non-Fatal	Electrocution of lineman while changing consumer's MCB during meter replacement work.					
3	Kh no 433, Property no 44, Office no 3 S/F, Veer Savarkar Block, Shakarpur, Near Govt School Delhi, Laxmi Nagar Victim: Unknown	5 July 19	Fatal	Electrocution from illegal taping of service cable.					
4	Char Khamba, Main Wazirabad Road, Mandoli Ext., Nand Nagri Victim: Animal	27 July 19	Fatal	Electrocution of a cow and a bull due to current leakage from high mast pole.	.				
5	Sub-station no 6, Mixed Housing, Div-MVR III Victim:Linemen AMC (Sh. Karoo Singh and Sh. Om Prakash Meena)	02 August 19	Non Fatal	Flash from LT-ACB while attempting theft inside sub-station					
6	11KV Sub-station Sh. Nova Loni Road, GT Road Victim : Sh. Manish	10 September 19	Non Fatal	Theft of electricity					
7	Nikka Plastic, Tukhmirpur, Karawal Nagar Victim : AMC Lineman (Sh. Netra Pal Singh)	19 October 19	Non-Fatal	Fall from the pole after completion of work					
8	H.No. E-2/ 105,Gali No.3, 4 ½ Pusta, Sonia Vihar, Delhi usta, Sonia Vihar, Delhi Victim : Manish Singh	24 October 19	Fatal	Electrocution while LED decoration at home.					
9	Gali No. 3, D Block, Ashok Nagar, Delhi -93. Victim - AMC Lineman Sh. Pappu Singh-	02 December 19	Fatal	Slipped from ladder after attending the complaint on Pole No M047 while he was getting down the ladder.					