Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: Jul' 2022
Year: 2022

Sl. No.	Location Of Accident and Details Of Victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	An accident occurred on 13/04/22 at around 12:55 PM. Mr. Kishan Lal (ALM, FLC- S.E.) has received minor burns due to flash.	13.04.2022	Non-Fatal (Employee)	-	-	-	-	-	-
2	An Accident occurred while a lineman was attending complaint at Pole No-KWNE633, Gali No-23, Rajiv Gandhi Nagar. The lineman fell and became unconscious.	26.04.2022	Fatal (Employee)	-	-	-	-	-	-
3	Minor flash occurred to 2 private workers during execution of pipeline work while working through drill for taking water connection from main pipeline.	01.05.2022	Non-Fatal (Public 2)	-	-	-	-	-	-
4	A PCR complaint received at 21:12 regarding current in pole at Ambedkar Jhuggi. Due to water logging a boy got electrocuted.	04.05.2022	Fatal (Public)	-	-	-	-	-	-
5	An accident occurred on 24.05.22 at around 17:21 Hrs . Mr. Karan got flash while doing white wash in newly &illegally constructed premises as vertical clearance was very low.	24.05.2022	Fatal (Public)	-	-	-	-	-	-
6	A lady got electrocuted at C-33 Chader Vihar , Gali No. 1,Mandawali and admitted to Max hospital	31.05.2022	Non-Fatal (Public)	-	-	-	-	-	-
7	Around 18:40 Hrs digging work to repair the faulty LT cable of Div. Chandni Chowk from Kucha Ghasi Ram substation to Gali Kandley Kasan carried out near Shop No. 297 Main Road Chandni Chowk was being carried out by hammering (Electric Hammer) because there is very heavy RCC (approx. 300 MM thick) which is not possible to break with out electric Hammer. During digging, bit of Hammer touched with live cable which was casted in RCC and a flash occurred on the hand of Mr.Ranveer. Due to this, he got minor burn on his hand. Immediately AM(FLC) Sh. N K Pant shifted him in LNJP hospital in emergency. Dressing done by doctors on his hands.	03.06.2022	Non-Fatal (Outside Agency)						
8	1 no. cow and 1 no. bull found dead near PWD Street Light Iron Pole at Kotla Village In front of 13/2 Kotla village (PCC Pole no E745 and Street light pole no NA)	16.06.2022	Fatal (Animals 2nos.)						
9	A labour got electrocuted at Construction site at 2404-2405 Tilak Street Chuna Mandi PHG.	17.06.2022	Fatal (Public 1 nos.)						
10	A wandering cow at 11703/3 Mars Good Carrier ,ram Kumar Marg,PWD Street light pole got electrocuted.	17.06.2022	Fatal (Animals 1nos.)						

11	A person got electrocuted at 14/3642 Regarpura, Karol Bagh while opening the shutter of shop due to current leakage in consumer's internal wiring.	20.06.2022	Fatal (Public 1 nos.)						
12	A PCR complaint received (22070301154) regarding the electrocution of a person at N- 21/B 2 Dilshad Garden.	03.07.2022	Fatal (Public 1 nos.)						
13	DJB has laid 2 core cable to supply the feeder pillar outside its building Near 140 MGD WTP, DJB, Sonia Vihar Delhi, there was a joint in it due to which a buffalo got electrocuted.	17.07.2022	Fatal (Animal 1 nos.)						
14	PCR complaint regarding current in house received at 1:16 Hrs on 30.07.2022. Lineman reached site and checked thoroughly & found no leakage at site.As per neghbours a person Neelu (Vinay) got electrocuted while trying to repair the 25KVA HVDS DTR fuse himself.	29.07.2022	Fatal (Public 1 nos.)						

(Signature of the Licensee)