Restoration of Power Supply Format-III

Name of Company **BSES Yamuna Power Ltd, Delhi**
Period of Report **June**
Year **2022**

Service Area	Standard wrt AT&C losses			Pending complaint of the previous	Complaint received during the month	Total Complaint	Complaints attended during the			Balance complaint to be attended
3	Upto 10%	More than 10% an d upto 20%	More than20%				Within Specified Time	Beyond specified time	Total	
1	2			3	4	5=3+4	6	7	8=6+7	9=5-8
Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement	Within three hours	Within four hours	Within six hours	57	57721	57778	57329	326	57655	123
Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	Within two hours	Within three hours	Within four hours	4	595	599	580	18	598	1
Continuous power supply failure requiring replacement of distribution transformer	Within six hours			0	7	7	7	0	7	0
Continuous scheduled power outages	Within 12 hours or restoration of power supply by 6PM			0	285	285	285	0	285	0
Replacement of burnt meter or stolen meter	Restoration of supply within three hours either by bypassing the			0	2245	2245	2243	0	2243	2
Continuous power failure affecting consumers connected through High Voltage Distribution System **(HVDS)**				1	59	60	57	2	59	0