Format II

Action taken report for safety measures complied for the accidents occurred

Name of Company: BSES YAMUNA POWER LTD, NEW DELHI
Period of Report: Sep' 2022
Year: 2022

Sl. No.	Location Of Accident and Details Of Victim	Date of occurrence	Type of accident	Cause of accident	Findings of CEI/EI/AEI	Remedies suggested by CEI/EI/AEI in various cases	Whether the remedy suggested is complied	Action taken to avoid recurrence of such accidents	Amount paid as compensation
1	Location: Dhruva Apartment, IP Extension, Laxmi Nagar An accident occurred on 13/04/22 at around 12:55 PM. Mr. Kishan Lal (ALM, FLC- S.E.) has received minor burns due to flash.	13.04.2022	Non-Fatal (Employee)	-	-	-	-	-	-
2	Location: Pole.No-KWNE633, Gali No-23, Rajiv Gandhi Nagar, Karawal Nagar An Accident occurred while a lineman was attending complaint at Pole No-KWNE633, Gali No-23, Rajiv Gandhi Nagar. The lineman fell and became unconscious.	26.04.2022	Fatal (Employee)	-	-	-	-	-	-
3	Location: Near Sarvodaya School, opposite Radhu palace office, LNR Minor flash occurred to 2 private workers during execution of pipeline work while working through drill for taking water connection from main pipeline.	01.05.2022	Non-Fatal (Public 2)	-	-	-	-	-	-
4	Location: Nursery Jhuggi Geeta Colony, Krishna Nagar A PCR complaint received at 21:12 regarding current in pole at Ambedkar Jhuggi. Due to water logging a boy got electrocuted.	04.05.2022	Fatal (Public)	-	-	-	-	-	-
5	Location: E 57/A-182 Jhuggi Sunder Nagri Delhi An accident occurred on 24.05.22 at around 17:21 Hrs . Mr. Karan got flash while doing white wash in newly &illegally constructed premises as vertical clearance was very low.	24.05.2022	Fatal (Public)	-	-	-	-	-	-
6	Location: C-33, Chander Vihar, Gali No 1, Mandawali, LNR A lady got electrocuted at C-33 Chader Vihar , Gali No. 1,Mandawali and admitted to Max hospital	31.05.2022	Non-Fatal (Public)	-	-	-	-	-	-
7	Location: In front of Shop 297, Main Road Chandi Chowk Around 18:40 Hrs digging work to repair the faulty LT cable of Div. Chandni Chowk from Kucha Ghasi Ram substation to Gali Kandley Kasan carried out near Shop No. 297 Main Road Chandni Chowk was being carried out by hammering (Electric Hammer) because there is very heavy RCC (approx. 300 MM thick) which is not possible to break with out electric Hammer. During digging, bit of Hammer touched with live cable which was casted in RCC and a flash occurred on the hand of Mr.Ranveer. Due to this, he got minor burn on his hand.	03.06.2022	Non-Fatal (Outside Agency)						

8	Location: Kotla Road, Near Kotla Village, MVR I&II 1 no. cow and 1 no. bull found dead near PWD Street Light Iron Pole at Kotla Village In front of 13/2 Kotla village (PCC Pole no E745 and Street light pole no NA)	16.06.2022	Fatal (Animals 2nos.)						
9	Location: 2405-05 Tilak Gali Chuna Mandi, PHG A labour got electrocuted at Construction site at 2404-2405 Tilak Street Chuna Mandi PHG.	17.06.2022	Fatal (Public 1 nos.)						
10	Location: In front of 11073/3 opposite Mars Good carriers, Ram Kumar Marg Pahar Ganj, (PCC Pole no NA and Street light pole no NA) A wandering cow at 11703/3 Mars Good Carrier ,ram Kumar Marg,PWD Street light pole got electrocuted.	17.06.2022	Fatal (Animals 1nos.)						
11	Location: 14/3642 Regarpura, Karol Bagh, SRD A person got electrocuted at 14/3642 Regarpura, Karol Bagh while opening the shutter of shop due to current leakage in consumer's internal wiring.	20.06.2022	Fatal (Public 1 nos.)						
12	Location: N-21/ B2 Dilshad Garden A PCR complaint received (22070301154) regarding the electrocution of a person at N- 21/B 2 Dilshad Garden.	03.07.2022	Fatal (Public 1 nos.)						
13	Location: Near 140 MCD WTP, DJB,Sonia Vihar , Delhi DJB has laid 2 core cable to supply the feeder pillar outside its building Near 140 MGD WTP, DJB, Sonia Vihar Delhi, there was a joint in it due to which a buffalo got electrocuted.	17.07.2022	Fatal (Animal 1 nos.)						
14	Location: Gali Nos. 4, Milan Garden, Nand Nagri PCR complaint regarding current in house received at 1:16 Hrs on 30.07.2022. Lineman reached site and checked thoroughly & found no leakage at site. As per neighbours a person Neelu (Vinay) got electrocuted while trying to repair the 25KVA HVDS DTR fuse himself.	29.07.2022	Fatal (Public 1 nos.)						
15	Location: Pole no YVR J058 (IInd Pusta Usmanpur Village), Ghonda , YVR A buffalo got electrocuted at Pole YVRJ058 Iind Pusta Usmanpur from an unauthorised wire connected to LV network which was tightened on street light clamp going for jhuggis for electricty theft.	04.08.2022	Fatal (Animal 1 nos.)						
16	Location: Indira camp j.j.colony, Hasanpur A PCR Complaint received (D-LNR control room)at 16.45hrs.i.e.Fire on tree at Hasanpur area. The Line/man reached at site and put off the supply. At site, it came in notice from public that one man got electrocuted due to touching the EHV LINE through wooden stick while he was trying to remove cloth from EHV line. Due to this some meters and s/l got burnt. Also, the EHV CKT.from GH-2 Grid to Industrial area grid tripped off at 16.30 hrs. due to this as confirmed from system control. The EHV line passing above the Indira camp j.j.colony, Hasanpur.	11.08.2022	Non-Fatal (Public 1 nos.)						
17	Location: Main 20 Ft road , Saboli Extn, Near Pal Chowk ,NNG A PCR complaint received at 16:56hrs regarding fire in house. Lineman attended it and found that a girl aged around 8 years went to roof of a house for	15.08.2022	Fatal (Public 1 nos.)						

	collecting kite. she came in contact with 11kV O/H line and got electrocuted.								
18	Location: A16, Preet Vihar, LNR A child was trying to insert electrical wire for fan in extension box one by one and the boy was bare feet, he came in contact with live electric wire at .	17.08.2022	Fatal (Public 1 nos.)						
19	Location: Pole Nos. KWNXE48, F-86 Ankur enclave, KWN A 10 year boy met with non-fatal accident while removing the kite from DD fuse of HVDS transformer and came in contact with the network at Pole Nos. KWNXE48, F-86 Ankur enclave, KWN	18.08.2022	Non-Fatal (Public 1 nos.)						
20	Location: Sonia Vihar A girl met with a fatal accident when the gate of the Sonia Vihar Grid fell over her.	12.09.2022	Fatal (Public 1 nos.)						
21	Location: Avanti bai chowk pul mithaai peeli kothi lahori gate Delhi -6. A complaint of current leakage / electrocution of a person at site " Peeli kothi / pul mithaai near police chowki" received by GNIT on duty CCK at 20:17 hrs / dated 15-09-2022. Line man Sh.Pappu along with ALM Sh.Dashrath reached at site immediately & put off / disconnect the power supply the street light till the terminal pole at Avanti bai chowk pul mithaai peeli kothi lahori gate Delhi -6.	15.09.2022	Fatal (Public 1 nos.)						
22	Location: Banarsi Clinic substation, Yamuna Vihar LR team was deputed to remove illegal cable at Banarsi Clinic substation (SLM074) on dt. 22.09.2022. During the work LTACB was put Off to carry out the necessary work for 10 minutes. After removing the necessary illegal cable lineman Sachin went to restore the supply , for this he charged the LTACB and then as he push the ON- button, a sudden flash occurred in LTACB. In this flash, Lineman Sachin got minor injury.	22.09.2022	Non-Fatal (Employee)						
23	Location: E-131, Ganesh Nagar Pandav Nagar, Delhi-92. Vinod Kr L/M was allotted the work of shifting three meters at Smt Tara Devi, E-131, Ganesh Nagar Pandav Nagar, Delhi-92. As per LM he started opening the hanging bus bar, but there was a problem in opening the clip, so he removed the right hand gloves and opened the clip of bus bar, as soon as the bus bar was opened, flashed occured and he got minor burnt on his right hand.	29.09.2022	Non-Fatal (Employee)						

(Signature of the Licensee)